

# **Process Safety Management in Marketing locations**

**Critical Safety issues in Marketing locations –  
Striving for improved performance**

**Design of Fire Safety System in POL Locations**

**A.K.Gupta  
DGM(HSE) CO , IOCL**

# Design of Fire Safety System in POL Locations


- OISD 117
- OISD 244 ( Draft V)

# Design of Fire Safety System in POL Locations

## Stipulations in OISD Standards needing special attention


- Two largest Fire contingencies if total tankage > 30 TKL

Cone Roof Tank Farm




Area - I

Floating Roof Tank Farm



Area - II

# Design of Fire Safety System in POL Locations




## (A) Fire water requirement for area – I ( Tank farm containing CR Tanks )

- Cooling ( exposure protection) X-1
- Full surface fire ( foam application @ 5 lpm/m<sup>2</sup>) X-2
- Supplementary water ( 4X36 M<sup>3</sup>/Hr ) X-3
- **Total** **X**

➤ OISD does not envisage fighting Full surface fire in CR tanks using HVLRMs while working out fire water requirement.

# Design of Fire Safety System in POL Locations



## (B) Fire water requirement for area – II ( Tank farm containing FR Tanks )

- Cooling ( exposure protection) \* Y-1
- Rim seal fire ( foam application @ 12 lpm/m<sup>2</sup>) Y-2
- Supplementary water ( 4X36 M<sup>3</sup>/Hr ) Y-3
- **Total** **Y**

\* Tank on Fire 29 M X 15 M being largest **NO**  
28 M X 14 M ( more cooling water required)

# Design of Fire Safety System in POL Locations

## (C) Fire water requirement – FR Tank on full surface Fire

- Cooling ( exposure protection) Z-1 (= Y-1)
- Full surface Fire ( foam application @ 8.1 lpm/m<sup>2</sup>) \$ Z-2
- Supplementary water ( 4X36 M<sup>3</sup>/Hr ) Z-3
- **Total** Z


**\$ - Potential foam losses from wind and other sources to be added as per design requirement ( HOW MUCH ? )**

Fire Water Required:

- **Z** if  $Z > X+Y$
  - **X+Y** if  $Z < X+Y$
- **One FR Tank on full surface fire equivalent to Two Largest Fire contingencies**


# Design of Fire Safety System in POL Locations

Minimum residual pressure of **7 kg / cm<sup>2</sup> (g)** at hydraulically remotest point



Head loss in each segment should be based on design flow in that segment to arrive at residual pressure at hydraulically remotest point.

# Design of Fire Safety System in POL Locations



Spray nozzles be directed radially at a distance not exceeding **60 cm** from Tank surface



# Design of Fire Safety System in POL Locations


Clause 4.3.7 (j) – Well laid procedures & plans shall be made & put into use of HVLRMs to combat emergency without loss of time.

Special attention required for Foam recouplement arrangement



# Design of Fire Safety System in POL Locations


What if all tanks are in a single dyke?



Some tanks may not be within horizontal range of HVLRLMs

# Design of Fire Safety System in POL Locations

Fire water ring around tank in two parts



# Design of Fire Safety System in POL Locations

## Common observations needing correction / attention

- RA to be done at the layout stage.
- Mismatch of RPM of Fire Engine & pump
- Fire Engine incapable of reaching desired RPM to deliver Q & H as per design / requirement
- Installation of remote control panels adjacent to HVLRMs.
- Centralized Foam feeding arrangement



# Design of Fire Safety System in POL Locations


## Common observations needing correction / attention

- Inadequate pressure in Fire Hydrant
- Inadequate replenishment capability of Fire Water
- Incorrect placement of monitors
- HVLRM not visible from Remote panel.
- Mismatch of designed heads of Fire pumps
- Ineffective quality management of Fire Water
- Fire system not working in Auto mode
- Incorrect storage and handling of Foam and inadequate foam inventory.
- Improper Mutual aid arrangement . Header to header connection instead of header to water tank.

# Design of Fire Safety System in POL Locations

## Points to Ponder


- Can requirement of Remote control, variable Flow HVLRMs be relaxed for IFRTs?
- Fire water hydrant header size augmentation - 49  $\pi$  sq inch to be augmented to 98  $\pi$  sq inch.



# Design of Fire Safety System in POL Locations

## Points to Ponder

- Will it not be a good idea to provide manifold (for connecting portable HVLRMs) on hydrant headers around Floating Roof Tanks dyke - To take care of situation when a fixed HVLRM in critical position is rendered useless due to wind velocity / malfunctioning etc.?



- Issues:
1. Limitation of jet throw
  2. What if monitor malfunctions
  3. No variable flow required
  4. Better flexibility available in case of mobile equipment.
  5. **Minimum 4 fixed 1000 GPM HVLRMs required. 1 portable 1000 GPM HVLRM would have worked.**

# Design of Fire Safety System in POL Locations

## Points to Ponder – contd

- What is impact of wind velocity ( > 4 km / hr) or inlet pressure < 7 kg / sq. M on performance of HVLRMs ?
- Criteria to be followed for positioning of a fixed HVLRM in such a way that it can be operated manually.
- Can we relax requirement of variable flow, remote control features of HVLRMs and make it need based ?
- Circumstances under which a location to be treated as “ **not meeting safety distance norms as per OISD**” for the purpose of provision of fixed HVLRMs”
- Training needs / SOPs



**Thanks**