

RTI-15-15  
BY REGISTERED AD

02.08.2015

From:  
Suryakant M. Vaidya  
Flat no.3, Lilavati Apartment,  
Near Navrachana ITI, Savarkar Nagar,  
Gangapur road  
Nasik -422013

To,

The Public Information Officer  
Oil Industry Safety Directorate  
Govt of India  
Ministry of Petroleum and Natural Gas  
8th Floor Tower A, OIIB Bhavan  
Plot No 2, Sector 73  
NOIDA 201301

Subject : Application under the Right to Information Act, 2005 to obtain information and/or documentations pertaining to Rim Seal Fire Detection and Extinguishing System for class A external floating roof Tanks.

---

Respected Sir

I am filing this RTI application to seek the following information from your good selves:

- i. Is compliance of OISD 116 and 117 Standards covered during inspection of commissioned Floating Roof Storage Tanks?
- ii. If yes, are the inspected tanks OISD 116 and 117 compliant?

To the best of our knowledge all the above information, is within the public domain and does not fall within the restrictions contained in section 8 and 9 of the RTI act and requires to be disclosed.

In case we are required to pay certain extra fees for the photocopies requested by us please do inform us and we shall arrange for it at the earliest.

Please find enclosed postal order bearing number 99E769/30 dated 03-08-2015 for Rs 10/- as fees for filing this RTI application with your office.

In case the subject matter or any of the information is held or the same is related to another public authority, you are requested to transfer this application or such part of it as may be appropriate to that public authority with the intimation to the undersigned as per section 6(3) of the RTI act.

It is further submitted that the information requested herein above may be provided by post to the undersigned.

Thanking You

Yours faithfully,



Suryakant M. Vaidya

Enclosed: As stated



तेल उद्योग सुरक्षा निदेशालय  
OIL INDUSTRY SAFETY DIRECTORATE



भारत सरकार, पेट्रोलियम और प्राकृतिक गैस मंत्रालय  
8वां तल, टॉवर-ए, ओ.आई.डी.बी. भवन,  
प्लॉट नं. 2, सेक्टर-73, नोएडा-201301

Government of India, Ministry of Petroleum & Natural Gas  
8th Floor, Tower-A, OISD Bhawan  
Plot No. 2, Sector-73, NOIDA - 201301

दूरभाष/Tel. : +91-120-2593800, 2593801

फैक्स/Fax : +91-120-2593802, 2593858

वेबसाइट/Website : www.oisd.gov.in

No: OISD/RTI/09

Date: 21.08.2015

**Mr. Suryakant M. Vaidya,**  
**Flat no.3, Lilavati Apartment,**  
**Near Navrachana ITI, Savarkar Nagar,**  
**Gangapur Road,**  
**Nasik-422 013**

**Sub: Information sought under RTI Act, 2005.**

Sir,

This has reference to RTI application no. RTI-15-15 dated 02.08.2015 which was received in our office on 12.08.2015, the requisite information pertaining to questions on Rim Seal Fire Detection and Extinguishing System for Class-A external floating roof tanks are as under:

Question 1: Is compliance of OISD 116 and 117 Standards covered during inspection of commissioned Floating Roof Storage Tanks?

Answer: Yes, Compliance of OISD STD 116 & 117 provisions are covered during inspection of commissioned Floating Roof product storage Tanks.

Question 2: If yes, are the inspected tanks OISD 116 and 117 compliant?

Answer : Provisions of OISD STD 117 is applicable to POL Marketing Installations and Pipe line Installations while OISD-STD-116 is applicable to Refineries and Gas Processing Plants. Tanks are inspected according to the provisions of OISD STD 116 & 117 and most of the tanks are OISD STD-116 & 117 complied and some are in advance stage of compliance.

*M. Gupta*  
21.08.15

(M. Gupta)  
Addl. Director (Env) & CPIO